

# Product Compliance Certificate



**Certificate Number: 5014091S230006-01A**

Certification is based on the type testing according to below named standards and production is monitored by an Initial and Annual Follow up Inspection Service.

**Notice to Authorities:**

This certificate indicates that a third party Accredited Body has tested and verified that the products listed comply with the relevant harmonized standards to directives listed on this certificate. The manufacturer may indicate compliance to said directive by signing a Declaration of Conformity to products identical to the tested samples.

In addition, annual factory inspection has been performed for further verification of compliance. Intertek requests all whom may be concerned to allow products entry into the European market without delay or prejudice. The applicant may rightfully use this certificate to mark their products with the ETL<sup>EU</sup> mark identified above.

Intertek is a leading international provider of quality and safety services to a wide range of global and local industries. Intertek's laboratories are included in IECCE CB scheme as operational CBTL and hold several local accreditations.

For further information:  
Email: [ETL.EU@intertek.com](mailto:ETL.EU@intertek.com)  
Website: [www.intertek.com/ETLeu](http://www.intertek.com/ETLeu)

Or Certification Body:  
Intertek Testing Services Ltd.  
Shanghai  
West Area, 2<sup>nd</sup> Floor, No. 707,  
Zhangyang Road, China  
(Shanghai) Pilot Free Trade Zone,  
Shanghai, P. R. China

**Applicant**

Zhejiang Chint Electrics Co., Ltd.  
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang  
P. R. China

**Manufacturing Site**

Zhejiang Chint Electrics Co., Ltd.  
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang  
P. R. China

**Product Name**

Earth leakage circuit-breakers

**Trademark**



**Model Number(s)**

NXBLE-63Y

**Description**

Details see attachment

**Test Report No**

2306A0286SHA-001

**Standards/Directives**

EN 60947-2: 2017+A1:2020; IEC 60947-2: 2016+A1:2019  
SANS 60947-2: 2020; SANS 556-2-1: 2018; VC8035: 2016

**Issued Date**

August 14, 2023

**Validity**

August 13, 2028

Maximum 5 years or the validity limitation of the standards/directives used, whichever is sooner.

If the product is to be marketed in different European countries, it must be provided with a certified plug appropriate for each country. Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2014/35/EU. Other EU directives may apply.

Gary Hu



## Attachment to Certificate Number: 5014091S230006-01A

### Type description:

$U_e = 240V\sim$  for 1P+N

$I_n = 63A$

$I_{cu} = I_{cs} = 4,5kA$

$I_{\Delta n} = 30mA$  type AC

$I_{\Delta m} = 2000A$

Cat. A,  $I_i = 10I_n$ ,  $U_{imp} = 4kV$ ,  $U_i = 500V$ , 50/60Hz