



Ref. Certif. No.

HU-004581

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	DC circuit breaker
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing, 325603 Zhejiang P.R. China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing, 325603 Zhejiang P.R. China
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing, 325603 Zhejiang P.R. China
Ratings and principal characteristics	Type of release: Thermo-magnetic; Selectivity Category: A; 2P appearance; Ue=80VDC; In=80/100/125A; Icu=Ics=10kA; Uimp=4kV; Ui=500V
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	CB-125CXZ
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN23USFV 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-09-12

Signature: Wencai Zhang

10/061SMD 2022-07 rke-fix