

Certificate

Sertifikat Produk Penggunaan Tanda SNI

Standard No. & Title/ No. & Judul standar	SNI 8528-1:2018 (IEC 60898-1:2015,MOD) (Lengkapan listrik – Pemutus sirkit untuk proteksi arus lebih untuk instalasi rumah tangga dan sejenis - Bagian 1: Pemutus sirkit untuk operasi a.b.)
Registration No./ No. registrasi	00399.TUR.MC.0723
Certification Agreement Ref. Ref. Perjanjian Sertifikasi	CA-230082
Certificate No./ No. sertifikat	824 230205

PT TUV Rheinland Indonesia certifies
in accordance to product certification system No. 5 refer to technical regulation Peraturan Menteri Energi dan Sumber Daya Mineral No. 7 Tahun 2021 for

Factory location : Zhejiang Chint Electrics Co., Ltd.
Lokasi Pabrik No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China 325603

Factory's representative : Wu Zhengwei
Penanggungjawab Produsen Certification Engineer

Representative Company in
Indonesia/Perusahaan PT CHINT INDONESIA
Perwakilan di Indonesia* JL. Pool PPD Pesing Poglar No.11, Komplek Prima Centre Blok C9-C10,
Desa/Kelurahan Kedaung Kali Angke, Kec. Cengkareng, Kota Adm.
Jakarta Barat, Provinsi DKI Jakarta, 11710

Company's representative : Ace Chang
Penanggung jawab Director

Product / Produk: MCB / Pemutus sirkit (MCB)

Brand: **CHINT**
Merek

Audit and Testing were performed. Proof has been furnished that the above requirements according are fulfilled.
Audit dan Pengujian telah dilakukan. Bukti kesesuaian terhadap persyaratan diatas telah terpenuhi.

Validity: The certificate is valid from 2023-07-28 until 2026-07-27
Masa berlaku *Sertifikat berlaku dari 2023-07-28 sampai dengan 2026-07-27*
The factory/manufacturer site is subject to annual surveillance audit with the due date for all future audits is 28-07 (dd-mm).
Audit survailan akan dilaksanakan setiap tahun dengan batas waktu audit berikutnya adalah 28-07 (tanggal-bulan).

Jakarta, 2023-07-28

PT TUV Rheinland Indonesia
Infinita Park Blok A56, B 92-93.
Jl. Dr. Sahardjo No. 45 Jakarta 12850

© TÜV, TÜV and TÜV are registered trademarks. Utilization and application requires prior approval.

Annex to Certificate

Standard/ standar	SNI 8528-1:2018 (IEC 60898-1:2015,MOD)
Certificate No./ No. sertifikat	824 230205
Importer name and address Nama dan alamat importir	PT CHINT INDONESIA JL. Pool PPD Pesing Poglar No.11, Komplek Prima Centre Blok C9-C10, Desa/Kelurahan Kedaung Kali Angke, Kec. Cengkareng, Kota Adm. Jakarta Barat, Provinsi DKI Jakarta, 11710
Business License Number : Nomor Induk Berusaha	9120107480452

Test Report No. / Nomor Laporan Pengujian	List of type or size in scope / Daftar tipe atau ukuran dalam cakupan
QI-23/04/0537	<p>NXB-63</p> <p>Ue = 220V/230V/240V~ (1P,1P+N,2P),380V/400V/415V~ (2P,3P,3P+N,4P); 50Hz/60Hz; Icn=Ics=6000A (except 2P,220V/230V/240V~); Icn=10000A, Ics=7500A (only for 2P,220V/230V/240V~) B/C/D-type</p>
QI-23/04/0538	<p>NXB-63H</p> <p>Ue = 220V/230V/240V~ (1P,1P+N), 380V/400V/415V~ (2P,3P,3P+N,4P); 50Hz/60Hz; Icn=10000A, Ics=7500A B/C/D-type</p>

Jakarta, 2023-07-28

PT TÜV Rheinland Indonesia
Infinia Park Block A56, B 92-93
Jl. Dr. Sahardjo No. 45 Jakarta 12850

© TÜV, TÜV and TÜV are registered trademarks. Utilization and application requires prior approval.