



Ref. Certif. No.

SE-108759M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone North Baixiang, Yueqing, Zhejiang China
Name and address of the manufacturer	Same as applicant
Name and address of the factory	Same as applicant
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NXB-63
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	220500316SHA-001, 220500316SHA-001A1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Date: 29 November, 2022



Signature:

Quan Li

**Rating and principal characteristics**

$U_n$ = AC220V/230V/240V (1P, 1P+N, 2P)

$U_n$ = AC380V/400V/415V (2P, 3P, 3P+N, 4P)

$I_n$ = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A

$I_{cs}$ =  $I_{cn}$ = 6000A (1P, 2P, 1P+N, 3P, 3P+N, 4P)

$I_{cs}$ = 7500A,  $I_{cn}$ = 10000A (2P, AC220V/230V/240V)

B-, C- & D-type, with switched neutral

**Additional information**

This certificate replaces previously issued certificate ref. No. SE-108759 dated 08 August 2022. A new certificate has been issued due to adding the reference temperature +50°C.

Date: 29 November, 2022

Signature:

