


# Test Verification of Conformity

Verification Number: 210300254SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the regulation(s) listed on this verification at the time the tests were carried out. Other standards and Regulations may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark regulations are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China 325603
Manufacturing site Name & Address:	Same as applicant
Product Description:	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Ratings & Principle Characteristics:	$U_n = AC220V/230V/240V$ (1P, 1P+N, 2P) $U_n = AC380V/400V/415V$ (2P, 3P, 3P+N, 4P) $I_n = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A$ B-, C- & D-type, $I_{cs} = I_{cn} = 6000A$ (except for 2P) $I_{cs} = I_{cn} = 6000A$ (2P, AC380V/400V/415V) $I_{cs} = 7500A, I_{cn} = 10000A$ (2P, AC220V/230V/240V)
Models/Type References:	NXB-63
Brand Name:	
Relevant Standards/Regulations:	BS EN 60898-1:2003+A1:2004+A11:2005+A12:2008+A13:2012 Electrical Equipment (Safety) Regulations 2016
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2019-02-28 to 2019-04-30
Test Report Number(s):	190300987SHA-001



Signature

Name: Oliver Wei  
Position: Manager  
Date: 08 April 2021