


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2002254R2

Moulded Case Circuit-Breakers (MCCBs)

Type designation:	DZ158-125H, DZ158-125
Certificate holder:	Zhejiang Chint Electric Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China
The product complies with the standard(s):	EN 60947-2:2017+A1
Date of expiry:	11 September, 2025
EU Directive information:	According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Intertek

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:




Date: 17 June, 2022

Henrik Wikström

APPENDIX:

Reference No. SE-S-2002254R2

Technical Data:

Type designation	DZ158-125H, DZ158-125
Rated voltage (V)	230/240V~ (1P), 400/415V~ (2P, 3P, 4P)
Rated current (A)	63, 70, 80, 90, 100, 125A
Frequency (Hz)	50/60
IP-Class	20
Trademark	
Test Report	210600852SHA-001, 210600852SHA-001 A1
Product information	Poles No 1P, 2P, 3P, 4P DZ158-125: $I_{cu} = I_{cs} = 6kA$ DZ158-125H: $I_{cu} = 10kA, I_{cs} = 7,5kA$ $I_i = 10I_n, 12I_n, \text{Cat. A}, U_{imp} = 4kV, U_i = 500V$ ref. temperature: +30°C, +40°C, +50°C and +55°C

Manufacturing Sites:

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R. China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

This certificate replaces previously issued certificate ref. No. SE-S-2002254R1, dated 26 August 2021. A new certificate has been issued due to a test verification of reference temperature has been added.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 17 June, 2022

Henrik Wikström