



Ref. Certif. No.

CN23803-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Air Circuit Breaker

Name and address of the applicant
Nom et adresse du demandeur

ZHEJIANG CHINT ELECTRICS CO., LTD.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

ZHEJIANG CHINT ELECTRICS CO., LTD.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory
Nom et adresse de l'usine

ZHEJIANG CHINT ELECTRICS CO., LTD.
No.1318, Binhai No.2 Avenue, Economic and
Technical Development Zone, Wenzhou City, Zhejiang
Province, P.R. China

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

CHINT

Model / Type Ref.
Ref. De type

NA1-4000,NA1-4000P,NA1-4000X

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

The latest CB No. is CN23803, dated 2012-06-15. This
modification is to add NA1-4000X.

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION **EDITION**
IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901- CB2017CQC-076215

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



CHINA QUALITY CERTIFICATION CENTRE

Date: Jul.27,2017

Signature:

Wang Kejiao

NA1-4000、NA1-4000P、NA1-4000X
Uimp:12kV;
Ui:1000V;
Ue: AC400V;
In: 2000A,2500A,2900A,3200A,3600A,4000A;
Over-current release: Electronic;
Ics: Ics=80kA;
Icu: Icu=100kA;
Icw: Icw=80kA/1s;
Selectivity category: B;
4P;
Suitability for insulation;
Auxiliary contact:
6NO6NC;
Ith: 6A;
AC-15: Ue/Ie: AC400V/0.75A,AC230V/1.3A;
DC-13: Ue/Ie: DC220V/0.27A,DC110V/0.55A


Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: Jul.27,2017

Signature:



Wang Kejiao