

IEC

IECEE  
CB  
SCHEME

Ref. Certif. No.

CN45047

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Air Circuit Breaker

Name and address of the applicant  
Nom et adresse du demandeurZhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.ChinaName and address of the manufacturer  
Nom et adresse du fabricantZhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.ChinaName and address of the factory  
Nome et adresse de l'usineNOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai,  
P.R.ChinaNote: When more than one factory, please report on page 2  
Note: Lorsque plus d'une usinem, veuillez utiliser la 2<sup>ème</sup> pageRatings and principal characteristics  
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

CHINT

Model / Type Ref.  
Ref. De type

NA8-2500H

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à laAs shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce CertificatPUBLICATION  
IEC 60947-2:2016(5th Edition)

EDITION

00901-CB2017CQC-078449

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

CHINA QUALITY CERTIFICATION CENTRE

Date: Oct.31,2018

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666  
Fax: +86-10-83886282website  
www.cqc.com.cn

CB 0045854



NA8-2500H  
Ui: 1000V  
Uimp: 12kV;  
Ue: AC380/400/415V, AC690V  
In: 630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A  
Over-current release: Electronic  
Ics: AC380V/400/415V: Ics=85kA; AC690V: Ics=65kA  
Icu: AC380V/400/415V: Icu=85kA; AC690V: Icu=65kA  
Icw: AC380V/400/415V: Icw=85kA/1s, Icw=50kA/3s;  
AC690V: Icw=65kA/1s, Icw=50kA/3s;  
Selectivity category: B;  
3P, 4P  
IP20(only front)  
Auxiliary contact (Body)  
4NO4NC, 6NO6NC:  
Ith: 6A  
AC-15: Ue/Ie: AC230V/1.3A, AC415V/0.75A  
DC-13: Ue/Ie: DC110V/0.55A, DC220V/0.27A  
Accessories with electronic circuits:  
Undervoltage release:  
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;  
Shunt release:  
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;  
Closing electromagnet:  
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Page 1 of 1

Additional information (if necessary)  
Information complémentaire (si nécessaire)

Date: Oct.31,2018

Signature:



Wang Kejiao