

Certificate



for European Product Safety

Reference No. 1512833

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Type designation NB1L₆₃

Certificate holder Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province,
CHINA

The product complies with the standard(s) EN 61009-1:2012+A1+A2

Date of expiry 12 June 2020

EU Directive information The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Bo Berglöv *Date* 12 June 2015
Page 1 of 4

**Intertek**
Appendix

Reference No. 1512833

Technical data

Type designation	NB1L-63
Rated voltage (V)	240
Rated current (A)	50, 63
Frequency (Hz)	50
IP-Class	20
Poles No.	1P+N
Brand name:	CHNT
Product information	$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type-AC $I_{cs} = I_{cn} = 6000A$, B-Type and C-Type

Type designation	NB1L-63
Rated voltage (V)	240
Rated current (A)	50, 63
Frequency (Hz)	50
IP-Class	20
Poles No.	2P
Brand name:	CHNT
Product information	$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type-AC $I_{cs} = I_{cn} = 6000A$, B-Type and C-Type

Type designation	NB1L-63
Rated voltage (V)	415
Rated current (A)	50, 63
Frequency (Hz)	50
IP-Class	20
Poles No.	3P
Brand name:	CHNT
Product information	$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type-AC $I_{cs} = I_{cn} = 6000A$, B-Type and C-Type

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1512833

Technical data

Type designation	NB1L-63
Rated voltage (V)	415
Rated current (A)	50, 63
Frequency (Hz)	50
IP-Class	20
Poles No.	3P+N
Brand name:	CHNT
Product information	$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type-AC $I_{cs} = I_{cn} = 6000A$, B-Type and C-Type

Type designation	NB1L-63
Rated voltage (V)	415
Rated current (A)	50, 63
Frequency (Hz)	50
IP-Class	20
Poles No.	4P
Brand name:	CHNT
Product information	$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type-AC $I_{cs} = I_{cn} = 6000A$, B-Type and C-Type

Manufacturing site(s)	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, CHINA
-----------------------	--

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.




Intertek
Appendix

Reference No. 1512833

This certificate, which includes production control, constitutes sufficient support for an EC Declaration of Conformity and CE marking, according to the principle of presumption of conformity, of the products according to the Low Voltage Directive 2006/95/EC.
This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed  Date 12 June 2015
Bo Berglöf

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.