

IEC**IECEE**

®

™

Ref. Certif. No.

CN59447

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Residual Current Operated Circuit-breaker With Integral Overcurrent Protection

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp: 4kV;Ui: 500V;Ue: AC230V;In: 6A, 10A, 16A, 20A, 25A, 32A, 40A; Instantaneous tripping current: Type B, Type C;IΔn: 30mA;Type of RCBO: Type AC, Type A; Electronic type; IΔm: 500A;Icn=Ics: 6000A;Number of poles: 1P+N (1 protected poles with a switched neutral pole)

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NB2LE-40ZT, NB2LE-40ZTB;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61009-2-2:1991(1st Edition);IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012, IEC 61009-1:2010/AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-104535

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Apr.04,2023

Signature:



Xie ZhaoXu

**CB 0071610**