

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Residual Current Operated Circuit-breaker With Integral Overcurrent Protection
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	Ui:690V; Uimp: 6kV; Ue: AC230V(1P+N), AC400V(3P+N); In: 6A,10A,16A,20A,25A,32A,40A,50A,63A,80A; Instantaneous tripping current: type C; Ics=Icn:6kA; IΔ n:10mA,30mA,100mA; Type of RCBO:A,AC; Electronic type;IΔ m:800A; Number of poles: 1P+N(With 1 protective poles and a switched neutral pole),3P+N(With 3 protective poles and a switched neutral pole); Suitable for isolation
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NB2LE-80ZT,NB2LE-80ZW
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010(3rd Edition) + AMD 1:2012 + AMD 2:2013; IEC 61009-1:2010;IEC 61009-2-2:1991(1st Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	03601-A-22CB0150-S


This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Feb.17,2023

Signature:



Xie ZhaoXu