

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electric Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Trade name: CHINT

Type/Model: NB310L

Ratings: 3P+N, Ue: 230 / 400 Vac, 50 / 60 Hz, In: 6, 10, 13, 16, 20, 25, 32, 40 A;
B and C type, I Δ n: 0,03, 0,3 A, type A and AC, without time-delay, Ics = Icn = 6 kA,
I Δ m = 3 kA, Energy limiting class 3

Manufactured by: Zhejiang Chint Electric Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

Requirements: BS EN 61009-1:2012 + A12:2016, BS EN 61009-2-1:1995

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3305783.50 issued on 2014-04-17, 3310570.50 issued on 2016-08-30, 3315767.50 issued on 2019-05-28 and 3319253.50 issued on 2020-11-17.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

Wenzhou, Zhejiang, 9 September 2021 Number: 3322483.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

J. Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

**UK
CA**