

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit-breakers with overcurrent protection

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China, 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Un= 240/415V~ (1P), 415V~ (2P,3P, 4P)
In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB7

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

201201176SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:



Leif Mattsson

Date: 26 January, 2021

Additional information

General Product information

Ue= 240/415V~(1P), 415V~(2P, 3P, 4P)

In=1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A, B-, C- and D- type

Icn= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63)

Ics= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63)

The product has also been checked according to EN 60898-1:2019

Date: 26 January, 2021

Signature: 