



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100117

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Type designation:	NB7
Certificate holder:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China, 325603
The product complies with the standard(s):	EN 60898-1:2019
Date of expiry:	26 January, 2026
EU Directive information:	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Intertek

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:

Date: 26 January, 2021

Leif Mattsson

APPENDIX:

Reference No. SE-S-2100117

Technical Data:

Type designation	NB7
Rated voltage (V)	240/415V~(1P), 415V~ (2P, 3P, 4P)
Rated current (A)	1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A
Frequency (Hz)	50/60
IP-Class	20
Poles No.	1P, 2P, 3P, 4P
Trademark	CHNT
Test Report	201201176SHA-001
Product information	Icn= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63) Ics= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63) B-, C- and D- type

Manufacturing Sites:

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China, 325603

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Leif Mattsson

Date: 26 January, 2021