

IEC**IECEE**

®

™

Ref. Certif. No.

CN51967

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Miniature Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NB8-63

Additional information (if necessary may also be
reported on page 2)

IEC 60898-1:2015(2nd Edition)

A sample of the product was tested and found
to be in conformity with

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2020CQC-093487

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>



Date: Nov.30,2020

Signature: _____

Lu Mei

CB 0059305

NB8-63

Uimp: 4kV;

Ui: 500V;

Ue: AC230V/AC400V(1P), AC230V(1P+N), AC400V(2P,3P,3P+N,4P);

In: 1A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A,50A,63A;

Instantaneous tripping current: B,C,D;

Ics:6kA;

Icn:6kA;

1P,1P+N(1 protected pole with a switched neutral pole),2P,3P,

3P+N(3 protected pole with a switched neutral pole),4P;

Applicable for isolation

Page 1 of 1

Additional information (if necessary)

Date: Nov.30,2020

Signature:



Lu Mei