

IEC**IECEE**

® TM

Ref. Certif. No.

CN52228

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:6kV; Ui:500V; Ue:AC230V(1P),AC400V(2P,3P,4P);
In:1A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A,50A,63A; Ics:7.5kA; Icu:10kA; Single
magnetic(No overload protection); Selectivity Category:A; 1P,2P,3P,4P; Applicable for isolation

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NB8-63M

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016(5th Edition); IEC
60947-2:2016/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-20CB0081-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.22,2020

Signature:

Lu Mei

CB 0059071