Issued to: Applicant: Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA

Manufacturer/Licensee: Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA

Product(s) : Electromagnetic contactor Trade name(s) : CHINT Type(s)/model(s) : NC1-40, NC1-50, NC1-65

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-4-1:2010 + A1: 2012;EN 60947-5-1:2004 + A1:2009; IEC 60947-4-1:2009 + A1:2012; IEC 60947-5-1:2003 + A1:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 20 December 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3310343.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

F.S. Strikwerda

Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Registered Arnhem 09085396

DEKRA D DA D DEK DEKRA D RA D DE

DEKRA KRA D DEKRA KRA D

DEKRA



ANNEX TO KEMA-KEUR CERTIFICATE 3310343.01

page 1 of 3

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data product trade name(s) type(s) General method of operation pollution degree main circuit number of poles rated frequency rated operational voltage (Ue) rated insulation voltage (Ui) rated impulse withstand voltage	::	
(Uimp) auxiliary circuit rated frequency utilization category conventional thermal current (Ith) rated current (Ie)	:	50/60 Hz AC-15, DC-13 10 A AC-15: 0,95 A at 380 Vac; 1,6 A at 220 V; 3,3 A at 110 Vac; 10 A at 36 V
rated uninterupted current (lu)	:	DC-13: 0,15 A at 220 Vdc; 0,3 A at 110 Vdc; 0,92 A at 24 Vdc AC-15: 0,95 A at 380 Vac; 1,6 A at 220 Vac; 3,3 A at 110 Vac; 10 A at 36 Vac DC-13: 0,15 A at 220 Vdc; 0,3 A at 110 Vdc;
rated conditional short-circuit current control circuits kind of current rated frequency rated control supply voltage (Us)		0,92 A at 24 Vdc 1 kA with fuse RT36-00 (NT00 gG 10 A 120 kA at 500 Vac) AC 50/60 Hz 24, 48, 110, 220, 380 Vac



ANNEX TO KEMA-KEUR CERTIFICATE 3310343.01

page 2 of 3

Product data - type NC1-40 rated operational current le (A) number of main circuit: conventional thermal current (Ith) rated conditional short-circuit current	:	40 A at 380/400/415 Vac (AC-3), 18,5 A at 380/400/415 Vac (AC-4) 34 A at 660/690 Vac (AC-3), 9 A at 660/690 Vac (AC-4) 3 or 4 60 A 3 kA
("r") rated conditional short-circuit current	:	50 kA
("lq") type of co-ordination SCPD	:	1 Fuse RT36-00(NT00), gG 63 A, 50 kA at 690 Vac
Product data - type NC1-50 rated operational current le (A)	:	50 A at 380/400/415 Vac (AC-3), 24 A at 380/400/415 Vac (AC-4) 39 A at 660/690 Vac (AC-3), 12 A at 660/690 Vac (AC-4)
number of main circuit: conventional thermal current (Ith) rated conditional short-circuit current ("r")	: :	3 or 4 80 A
rated conditional short-circuit current ("Iq")	:	50 kA
type of co-ordination SCPD	:	1 Fuse RT36-00(NT00), gG 80 A, 50 kA at 690 Vac
Product data - type NC1-65 rated operational current le (A)	:	65 A at 380/400/415 Vac (AC-3), 28 A at 380/400/415 Vac (AC-4) 42 A at 660/690 Vac (AC-3), 14 A at 660/690 Vac (AC-4)
number of main circuit: conventional thermal current (Ith) rated conditional short-circuit current ("r")	: :	3 or 4 80 A
rated conditional short-circuit current ("lq")	:	50 kA
type of co-ordination SCPD	: :	1 Fuse RT36-00(NT00), gG 80 A, 50 kA at 690 Vac



ANNEX TO KEMA-KEUR CERTIFICATE 3310343.01

page 3 of 3

Additional information

Nomenclature breakdown NC1-abc a= Rated operational current at AC-3, 380/400/415 Vac b= Number of auxiliary contacts 11=1NO+1NC, 4P contactor has no auxiliary contact (omitted) c= Number of main contacts 04=4NO; 08= 2NO+2NC, omitted for 3NO

TESTS

Test requirements

EN 60947-4-1:2010 + A1:2012 EN 60947-5-1:2004 + A1:2009 IEC 60947-4-1:2009 + A1:2012 IEC 60947-5-1:2003 + A1:2009

Test result

The test results are laid down in DEKRA test file 3310343.01 and test reports No. 3310343.50, 3301043.50 and 3301043.51.

Remarks

This certificate replaces the KEMA-KEUR certificate no. 2137361.01 issued on 2010-08-30.

Conclusion

The examination proved that all test requirements were met.

Tested by : Max Ma



Checked by : Eric Wang

Factory locations

Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. CHINA