Issued to: Applicant: Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA

Manufacturer/Licensee: Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA

Product(s) : Electromagnetic contactor Trade name(s) : CHINT Type(s)/model(s) : NC1-80, NC1-95

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-4-1:2010 + A1:2012;EN 60947-5-1:2004 + A1:2009;
 IEC 60947-4-1:2009 + A1:2012;IEC 60947-5-1:2003 + A1:2009;
 - an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 20 December 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3310344.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

-

F.S. Strikwerda Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Registered Arnhem 09085396

DEKRA D DEKRA D DEKRA D DEKRA D RA D DE

DEKRA KRA DD DEKRA KRA D

DEKRA



ANNEX TO KEMA-KEUR CERTIFICATE 3310344.01

page 1 of 3

SPECIFICATION OF THE CERTIFIED PRODUCT

| Product data | | |
|------------------------------------|---|---|
| product | 1 | Electromagnetic contactor |
| trade name(s) | 1 | CHINT |
| type(s) | : | NC1-80, NC1-95 |
| General | 2 | |
| method of operation | 1 | Electromagnetic |
| pollution degree | 5 | 3 |
| main circuit | 2 | |
| number of poles | ; | 3, 4 |
| rated frequency | 2 | 50/60 Hz |
| rated operational voltage (Ue) | : | 380/400/415 Vac, 660/690 Vac |
| rated insulation voltage (Ui) | 2 | 690 V |
| rated impulse withstand voltage | 2 | 8 kV |
| (Uimp) | | |
| auxiliary circuit | | Nas - |
| rated frequency | : | 50/60 Hz |
| utilization category | : | AC-15, DC-13 |
| conventional thermal current (Ith) | : | 10 A |
| rated current (le) | : | AC-15: |
| | | 0,95 A at 380 Vac; 1,6 A at 220 Vac; |
| | | 3,3 A at 110 Vac; 10 A at 36 Vac |
| | | DC-13: |
| | | 0,15 A at 220 Vdc; 0,3 A at 110 Vdc; |
| | | 0,92 A at 24 Vdc |
| rated uninterupted current (lu) | : | AC-15: 0,95 A at 380 Vac; 1,6 A at 220 Vac; |
| | | 3,3 A at 110 Vac; 10 A at 36 Vac DC-13: |
| | | 0,15 A at 220 Vdc; 0,3 A at 110 Vdc; |
| | | 0,92 A at 24 Vdc |
| rated conditional short-circuit | | 1 kA with fuse RT36-00 (NT00 gG 10 A 120 kA at 500 Vac) |
| current | • | T KA WIII 1036 11130-00 (11100 gG 10 A 120 KA at 500 Vac) |
| control circuits | | |
| kind of current | : | AC |
| rated frequency | : | 50/60 Hz |
| rated control supply voltage (Us) | | 24, 48, 110, 220, 380 Vac |
| inter control ouppij voltago (03) | • | |



ANNEX TO KEMA-KEUR CERTIFICATE 3310344.01

Product data - type NC1-80 rated operational current le (A) : 80 A at 380/400/415 Vac (AC-3), 37 A at 380/400/415 Vac (AC-4) 49 A at 660/690 Vac (AC-3), 17,3 A at 660/690 Vac (AC-4) number of main circuit: : 3 or 4 conventional thermal current (Ith) : 110 A or 125 A rated conditional short-circuit current : 5 kA ("r") rated conditional short-circuit current : 50 kA ("lq") type of co-ordination 2 1 SCPD : Fuse RT36-1(NT1), gG 100 A, 50 kA at 690 Vac Product data - type NC1-95

| rated operational current le (A) | | 95 A at 380/400/415 Vac (AC-3), 44 A at 380/400/415 Vac (AC-4) 49 A at 660/690 Vac (AC-3), 21,3 A at 660/690 Vac (AC-4) |
|--|--------|--|
| number of main circuit: | : | 3 or 4 |
| conventional thermal current (Ith) | : | 110 A or 125 A |
| rated conditional short-circuit current ("r") | : | 5 kA |
| rated conditional short-circuit current ("lq") | : | 50 kA |
| type of co-ordination SCPD | : : | 1 Fuse RT36-1(NT1), gG 100 A, 50 kA at 690 Vac |

Additional information

Nomenclature breakdown NC1-abcd a= Rated operational current at AC-3, 380/400/415 Vac b= Number of auxiliary contacts 11=1NO+1NC, 4P contactor has no auxiliary contact (omitted) c= Number of main contacts 04=4NO; 08= 2NO+2NC, omitted for 3NO d= Ith, it is 110 or 125 page 2 of 3



ANNEX TO KEMA-KEUR CERTIFICATE 3310344.01

page 3 of 3

TESTS

Test requirements EN 60947-4-1:2010 + A1:2012 EN 60947-5-1:2004 + A1:2009 IEC 60947-4-1:2009 + A1:2012 IEC 60947-5-1:2003 + A1:2009

Test result

The test results are laid down in DEKRA test file 3310344.01 and test reports No. 3310344.50, 3301043.50 and 3301043.51.

Remarks

This certificate replaces the KEMA-KEUR certificate no. 2137361.01 issued on 2010-08-30.

Conclusion

The examination proved that all test requirements were met.

Tested by : Max Ma



Checked by : Eric Wang

Factory locations Zhejiang CHINT Electrics Co., Ltd. No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA