

**IEC****IECEE**

Ref. Certif. No.

CN54871-M1

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

AC Contactor

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Zhejiang CHINT Electric Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance  
Industrial Zone, North Baixiang, Yueqing, Wenzhou, Zhejiang  
Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NC7-115,NC7-150,NC7-170;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN54871, dated 2021-09-26.  
The M1 certificate has been issued to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098429-M1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Oct.26,2023

Signature:

Xie ZhaoXu

NC7-115,NC7-150,NC7-170;

Ui:1000V;Uimp:8kV;

Ith:200A(NC7-115,NC7-150),275A(NC7-170);

Ue:AC380V/400V,AC660V/690V;

NC7-115:

AC-1:Ue/Ie:AC380V/400V/AC660V/690V/200A;

AC-3,AC-4:Ue/Ie:AC380V/400V/115A,AC660V/690V/86A;

NC7-150:

AC-1:Ue/Ie:AC380V/400V/AC660V/690V/200A;

AC-3,AC-4:Ue/Ie:AC380V/400V/150A,AC660V/690V/107A;

NC7-170:

AC-1:Ue/Ie:AC380V/400V/AC660V/690V/275A;

AC-3:Ue/Ie:AC380V/400V/170A,AC660V/690V/118A;

AC-4:Ue/Ie:AC380V/400V/150A,AC660V/690V/107A;

Us:AC110V,AC127V,AC220V,AC230V,AC240V,AC380V,AC400V,AC415V,50Hz;

AC220V,AC380V,60Hz;

AC110V,AC127V,AC220V,AC230V,AC240V,AC380V,AC415V,50/60Hz;

3P ;IP10;

Auxiliary contact:

NCF1-11C:1NO1NC;Ith: 10A;

AC-15:Ue/Ie: AC380V/400V/0.95A;

DC-13:Ue/Ie: AC220V/250V/0.15A;

NCF1-11C:1NO1NC;Ith: 10A;

AC-15: Ue/Ie:AC220V/230V/2.7A,AC380V/400V/1.5A;

DC-13: Ue/Ie:AC220V/0.3A

Additional information (if necessary)

Date:

Oct.26,2023

Signature:

谢肇煦

Xie ZhaoXu