

IEC**IECEE**

®

TM

Ref. Certif. No.

CN54767

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

AC CONTACTOR

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.2 Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang, Yueqing, Wenzhou, Zhejiang
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NC7-205;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098431

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.18,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0063829

NC7-205

Ui:1000V;

Uimp:8kV;

Ith:275A;

Ue:380V/400V,660V/690V;

AC-1:Ue/Ie:AC380V/400V/275A, AC660V/690V/275A;

AC-3,AC-4:Ue/Ie:AC380V/400V/205A, AC660V/690V/137A;

Us:AC110V,127V,220V,380V 50Hz;

3P;

Auxiliary contact:AX-3:

1NO1NC,2NO,2NC,4NO,4NC,2NO2NC,1NO3NC,3NO1NC;

Ith:10A;

AC-15:Ue/Ie:AC380V/400V/0.95A;

DC-13:Ue/Ie:DC220V/250V/0.15A


Page 1 of 1

Additional information (if necessary)

Date:

Sep.18,2021

Signature:



Xie ZhaoXu