



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220305007963

Product

AC Contactor

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NC8-115,NC8-150,NC8-170,NC8-115/N,NC8-150/N,NC8-170/N,NC8-115/W,NC8-150/W,NC8-170/W,NC8-115/W/N,NC8-150/W/N,NC8-170/W/N;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2023CQC0305-014054, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Sep.06,2023

Valid until: Dec.05,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE220305007963

NC8-115,NC8-150,NC8-170,NC8-115/N,NC8-150/N,NC8-170/N,NC8-115/W,NC8-150/W,N
C8-170/W,NC8-115/W/N,NC8-150/W/N,NC8-170/W/N

Ui:690V ;

Uimp:8kV;

Ith:200A(NC8-115,NC8-150),275A(NC8-170);

NC8-115:

AC-1:Ue/Ie:AC380V/400V/660V/690V/200A;

AC-3,AC-4:Ue/Ie:AC380V/400V/115A,AC660V/690V/86A;

NC8-150:

AC-1:Ue/Ie:AC380V/400V/660V/690V/200A;

AC-3,AC-4:Ue/Ie:AC380V/400V/150A,AC660V/690V/107A;

NC8-170:

AC-1:Ue/Ie:AC380V/400V/660V/690V/275A;

AC-3:Ue/Ie:AC380V/400V/170A,AC660V/690V/118A;

AC-4:Ue/Ie:AC380V/400V/150A,AC660V/690V/107A;

Us:AC/DC

110~127V,220~240V,380~415V(NC8-115,NC8-150,NC8-170,NC8-115/N,NC8-150/N,NC8-170/N); 50/60Hz;

AC/DC24~60V,48~130V,100~250V,250~500V(NC8-115/W,NC8-150/W,NC8-170/W,NC8-11



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE220305007963

5/W/N,NC8-150W/N,NC8-170/W/N); 50/60Hz;

3P;

IP10;

Auxiliary contact:

NCF1-11C

1NO1NC;

Ith:10A;

AC-15:Ue/Ie:AC380V/400V/0.95A;

DC-13:Ue/Ie: DC220V/250V/0.15A

NCF1-11C(Certified, certificate number is CN58175)

1NO1NC;

Ith:10A;

AC-15:Ue/Ie:AC220V/230V/2.7A,AC380V/400V/1.5A;

DC-13:Ue/Ie:DC220V/0.3A



CHINA QUALITY CERTIFICATION CENTRE