CN64326

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product AC Contactor

Name and address of the applicant Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,

Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,

Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory Zhejiang CHINT Electrics Co., Ltd.

Note: When more than one factory, please report on page 2 No.2, Changjiang Road, CHINT Intelligent Electric Appliance

Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,

P.R.China

Ratings and principal characteristics Uimp:12kV;Ui:1250V;Ue:AC1000V;NC8-1450:Ith:1450A;AC-1:Ue/I

e:AC1000V/1450A;

NC8-1700:Ith:1700A;AC-1:Ue/Ie:AC1000V/1700A;NC8-2100:Ith:21

00A;AC-1:Ue/Ie:AC1000V/2100A; Us:AC220V,AC380V,50/60Hz;Pole:3P

Trademark (if any) CHINT

Customer's Testing Facility (CTF) Stage used N/A

Model / Type Ref. NC8-1450,NC8-1700,NC8-2100;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018;IEC 60947-1:2007;IEC

60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which

forms part of this Certificate

00901-CB2023CQC-111028

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Date: Dec.29,2023



