



Ref. Certif. No.

CN59963

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electrics Co., Ltd.  
No.2, Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NC8-400,NC8-500,NC8-400/N,NC8-500/N,NC8-400/W,NC8-500/W,NC8-400/W/N,NC8-500/W/N;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-105225

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



Date: May.26,2023

Signature:

谢肇旭

Xie ZhaoXu

CB 0073614

NC8-400,NC8-500,NC8-400/N,NC8-500/N,NC8-400/W,NC8-500/W,NC8-400/W/N,NC8-500/W/N;

Ui:1000V;

Uimp:8kV;

Ith:450A(NC8-400,NC8-400/N,NC8-400/W,NC8-400/W/N);

Ith:630A(NC8-500,NC8-500/N,NC8-500/W,NC8-500/W/N);

NC8-400,NC8-400/N,NC8-400/W,NC8-400/W/N:

AC-1:Ue/Ie:AC220V/230V/450A,AC380V/400/450A,AC660V/690V/450A;

AC-3,AC-4:Ue/Ie: AC220V/230V/400A,AC380V/400/400A,AC660V/690V/303A;

NC8-500,NC8-500/N,NC8-500/W,NC8-500/W/N:

AC-1:Ue/Ie: AC220V/230V/630A,AC380V/400/630A,AC660V/690V/630A;

AC-3,AC-4:Ue/Ie: AC220V/230V/500A,AC380V/400/500A,AC660V/690V/354A;

Us: AC/DC110V~127V,220V~240V,380V~415V;

AC/DC48V~130V,100V~250V,250V~500V(NC8-400/W~500W,NC8-400/W/N~500/W/N);  
50/60Hz,DC;3P;

Auxiliary contact:

NCF1-11C/B

1NO1NC;Ith:10A;

AC-15:Ue/Ie:AC220V/230V/2.7A,AC380V/400V/0.95A,AC380V/400V/1.5A;


DC-13:Ue/Ie:DC220V/0.3A,DC220V/250V/0.15A

Page 1 of 1

Additional information (if necessary)

Date: May.26,2023

Signature:



Xie ZhaoXu