

# C E R T I F I C A T E



## of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50454533 0001

Report No.: 15073758 002

**Holder:** Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road,Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

**Product:** Magnetic Contactor  
(AC Contactor)

**Identification:** Type Designation : NC8-40/a/b  
a= 4 or Blank; b= N or Blank  
Standard : EN IEC 60947-4-1:2019 & EN 60947-5-1:2017  
Ratings : Main Circuit: AC-3/AC-4, Ue=220...415VAC,  
Ie=40A, Ue=660...690VAC, Ie=34A, Us= 24...415VAC, 50/60Hz,  
Ith=60A, Ui=690V, Uimp=8,0kA, 3P, 4P  
Serial No. : Engineering samples

Remark: Refer to test report 15073758\_001-002 for details

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 20.12.2019

Leeham Zhuang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

# C E R T I F I C A T E



## of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50454533 0002

Report No.: 15073758 002

**Holder:** Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

**Product:** Magnetic Contactor  
(AC Contactor)

**Identification:** Type Designation : NC8-50a/b  
a= 4 or Blank; b= N or Blank  
Standard : EN IEC 60947-4-1:2019 & EN 60947-5-1:2017  
Ratings : Main Circuit: AC-3/AC-4, Ue=220...415VAC,  
Ie=50A, Ue=660...690V, Ie=39A, Us= 24...415VAC, 50/60Hz,  
Ith=80A, Ui=690V, Uimp=8,0kA, 3P, 4P  
Serial No. : Engineering samples

Remark: Refer to test report 15073758\_001-002 for details  
This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 20.12.2019

Leeham Zhuang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

# C E R T I F I C A T E



of Conformity  
Low Voltage Directive 2014/35/EU

Registration No.: AN 50454533 0003

Report No.: 15073758 002

Holder: Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

Product: Magnetic Contactor  
(AC Contactor)

Identification: Type Designation : NC8-65/a/b  
a= 4 or Blank; b= N or Blank  
Standard : EN IEC 60947-4-1:2019 & EN 60947-5-1:2017  
Ratings : Main Circuit: AC-3/AC-4, Ue=220...415VAC,  
Ie=65A, Ue=660...690VAC, Ie=42A, Us= 24...415VAC, 50/60Hz  
Ith=80A, Ui=690V, Uimp=8,0kA, 3P, 4P  
Serial No. : Engineering samples

Remark: Refer to test report 15073758\_001-002 for details.  
This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 20.12.2019

Leeham Zhuang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Zhejiang Chint Electrics Co., Ltd.  
Chen chuihe  
-  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

Date : 20.12.2019  
Our ref. : LJH 01  
Your ref.: C.C.H.

**Ref : AN Certificate of Conf. Low Voltage D.**

Type of Equipment : AC Contactor  
Model Designation : See Certificate  
Certificate No. : AN 50454533 0001  
Report No. : 15073758 002

Dear Chen chuihe,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Leeham Zhuang

CC: Zhejiang Chint Electrics Co., Ltd.

Enclosure

证书的详细资料请登陆[www.tuvdotcom.com](http://www.tuvdotcom.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询