



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE230305008328

NC8-80/□□/□, NC8-100/□□/□, NC8-80/□□/□/N, NC8-100/□□/□/N

Uimp: 8kV; Ui: 690V;

Ue: AC220V/230V/240V, AC380V/400V/415V, AC660V/690V;

Ith: 125A;

NC8-80-100, NC8-80/Z-100/Z, NC8-80/4/Z-100/4/Z:

AC-1: Ue: 220V/230V/240V, AC380V/AC400V/AC415V, AC660V/690V, Ie: 125A;

AC-3, AC-4: Ue: AC220V/230V/240V, Ie: 80A, 100A;

Ue: AC380V/400V/415V, Ie: 80A, 100A;

Ue: AC660V/690V, Ie: 49A, 49A;

NC8-80/4-100/4, NC8-80/22-100/22:

AC-1: Ue: 220V/230V/240V, AC380V/AC400V/AC415V, AC660V/690V, Ie: 125A;

AC-3: Ue: AC220V/230V/240V, Ie: 80A, 100A;

Ue: AC380V/AC400V/415V, Ie: 80A, 100A;

Ue: AC660V/AC690V, Ie: 49A, 49A;

NC8-80/4-100/4, NC8-80/22-100/22:

AC-1: Ue: 220V/230V/240V, AC380V/AC400V/AC415V, AC660V/690V, Ie: 125A;

AC-4: Ue: AC220V/230V/240V, Ie: 37A, 44A;

Ue: AC380V/AC400V/415V, Ie: 37A, 44A;

Ue: AC660V/AC690V, Ie: 17.3A, 21.3A;

Us: NC8-80 ~ 100, NC8-80/4 ~ 100/4, NC8-80/22 ~ 100/22:

AC

24V, 36V, 42V, 48V, 110V, 120V, 127V, 220V, 230V, 240V, 277V, 380V, 400V, 415V, 440V, 460V, 480V, 600V, 660V; Rated frequency: 50/60Hz, 50Hz;

NC8-80/W ~ 100/W, NC8-80/4/W ~ 100/4/W, NC8-80/22/W ~ 100/22/W: AC/DC

100V-250V, 48V-130V, 24V-60V; Rated frequency: 50/60Hz(AC);

NC8-80/Z ~ 100/Z, NC8-80/4/Z ~ 100/4/Z: DC: 24V, 48V, 110V, 220V;

Number of poles: 3P, 4P;



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE230305008328

IP: NC8-80-100,NC8-80/W-100/W,NC8-80/Z-100/Z,NC8-80/4/Z-100/4/Z : IP20(Only the front), NC8-80/4-100/4,NC8-80/22-100/22,NC8-80/4/W-100/4/W,NC8-80/22/W-100/22/W:

IP10;

Auxiliary contacts:(body)

1NO+1NC;

Ith: 10A;

AC-15: Ue/Ie: AC380V/400V/415V/1.5A;

DC-13: Ue/Ie: DC220V/250V/0.3A



CHINA QUALITY CERTIFICATION CENTRE

