



Certificate of Compliance

Certificate: 70154015 **Master Contract:** 265766 (265766)

Project: 70210455 **Date Issued:** 2019-01-04

Issued to: Zhejiang CHINT Electrics Co Ltd
 No.1, CHINT Road,
 CHINT Industrial Zone,
 North Baixiang, Yueqing, 浙江 325603
 China
 Attention: Huimin Tian

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Huiyang (Hannah) Deng
 Huiyang (Hannah) Deng

PRODUCTS

CLASS - C321124 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers-Magnetic-
 CLASS - C321164 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers-Magnetic-Cert to US Stds-

Definite Purpose AC Contactors, open type, 3 Pole or 4 Pole, Models NCK5-20~32/3L, NCK5-20~32/3S, NCK5-20~32/4L, NCK5-20~32/4S, NCK5-40/3L, NCK5-40/4L, NCK5-40/3S, NCK5-40/4S.

Electrical Ratings:

Model	Definite purpose Rating(Three phase)							HP ratings		
	FLA			RES	LRA			Voltage	Single phase	Three phase
	240/ 277 V	480 V	600 V		240/ 277 V	480 V	600 V			
NCK5-20/3(4)L(S)	25	25	25	35	150	125	100	120	2	/
								240/277	5	10
								480	/	15
								600	/	20



Certificate: 70154015

Master Contract: 265766

Project: 70210455

Date Issued: 2019-01-04

NCK5-25/3(4)L(S)	25	25	25	35	150	125	100	120	2	/
								240/277	5	10
								480	/	15
								600	/	20
NCK5-30/3(4)L(S)	32	32	32	40	200	150	120	120	2	/
								240/277	5	10
								480	/	15
								600	/	20
NCK5-32/3(4)L(S)	32	32	32	40	200	150	120	120	2	/
								240/277	5	10
								480	/	15
								600	/	20
NCK5-40/3(4)L(S)	40	40	40	50	240	200	160	120	3	/
								240/277	7.5	10
								480	/	20
								600	/	25

Notes:

1. Short Circuit Rating - 5000 A rms, 600 V ac.
2. Electrical cycles table:

Device load type		Electrical cycles	Additional Mechanical cycles
Definite purpose	Motor (LRA/FLA)	30K	-
	Resistive	250K	-
Motor	Motor (hp)	1000	5000

3. Auxiliary Contact: NCF8-11C rated B600, Q600.
Auxiliary Contact: AX-10, rated 15A/250 Vac, B300, Q300.
4. For use only in complete products where the acceptability of the combination is determined by CSA Group
5. These devices should be used within their ratings as specified above.
6. Open type devices should be mounted in enclosures having adequate strength and thickness and in the intended manner and with acceptable spacings being provided.
7. The terminals are not suitable for field wiring. They are to be factory wired only and the suitability of the connection (including spacings between factory connectors) shall be determined.
8. Spacing from the exposed live metal parts to the enclosure walls shall be in accordance with the requirements of the overall equipment.



Certificate: 70154015

Project: 70210455

Master Contract: 265766

Date Issued: 2019-01-04

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 60947-4-1-14 - Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters
used in conjunction with
- CAN/CSA-C22.2 No. 60947-1-13 - Low-voltage switchgear and controlgear - Part 1: General rules
- UL 60947-4-1(3rd Edition) - Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters
used in conjunction with
- UL 60947-1 (5th Edition) - Low-voltage switchgear and controlgear - Part 1: General rules



Supplement to Certificate of Compliance

Certificate: 70154015

Master Contract: 265766 (265766)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70210455	2019-01-04	Update Report 70210455 to cover the correction of Class Number and Applicable Standard.
70154015	2017-09-12	AC Contactor, NCK5 series, UL Data part to accept, need to increase the test