


## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switch-disconnectors
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	$U_e = 230V\sim/240V\sim(1P), 400V\sim/415V\sim(2, 3, 4P)$ $I_e = 32, 40, 63, 80, 100, 125A$ $I_{cw} = 12I_e, 1s$ $I_{cm} = 20I_e; \text{Cat. AC-22A}$
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NH4-125
Additional information (if necessary may also be reported on page 2)	This certificate replaces CB certificate SE-105875, dated 06 September 2021. A new certificate has been issued due to additional mounting bolt M5.
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020 IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	210402354SHA-001, 210402354SHA-001 M1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature:



Leif Mattsson

Date: 05 July, 2022