

Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. This Certificate meets the requirements of a Recognised External Certification Scheme (RECS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Zhejiang Chint Electrics Co.,Ltd.	Other Name	
Address	No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing Zhejiang 325603 China		
Client ID	108754	Global-Mark File Number:	108754-005 System 1 Approval
Certification Number	GMA-517895	Revision Number	00
Certificate Standard(s)	AS 60947.3:2023 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units		
Type of Certification	Electrical Safety Product Scheme	Global-Mark Electrical Product Safety Certification Scheme	

CERTIFICATE DATES

Certificate Issue Date	29/01/2024
Certificate Last Update Date	
Certification Expiry Date	29/01/2029

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Switch-disconnector	CHINT	NH4-125 1P32A	Ue = 230/240V~ Ie = 32A Icw = 12Ie (384A/1s) Icm = 20Ie (640A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 1P40A	Ue = 230/240V~ Ie = 40A Icw = 12Ie (480A/1s) Icm = 20Ie (800A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 1P63A	Ue = 230/240V~ Ie = 63A Icw = 12Ie (756A/1s) Icm = 20Ie (1260A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 1P80A	Ue = 230/240V~ Ie = 80A Icw = 12Ie (960A/1s) Icm = 20Ie (1600A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 1P100A	Ue = 230/240V~ Ie = 100A Icw = 12Ie (1200A/1s) Icm = 20Ie (2000A) Cat. AC-22A

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager




Certificate of Suitability

Non declared	Switch-disconnector	CHINT	NH4-125 1P125A	Ue = 230/240V~ Ie = 125A Icw = 12Ie (1500A/1s) Icm = 20Ie (2500A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 2P32A	Ue = 400/415V~ Ie = 32A Icw = 12Ie (384A/1s) Icm = 20Ie (640A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 2P40A	Ue = 400/415V~ Ie = 40A Icw = 12Ie (480A/1s) Icm = 20Ie (800A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 2P63A	Ue = 400/415V~ Ie = 63A Icw = 12Ie (756A/1s) Icm = 20Ie (1260A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 2P80A	Ue = 400/415V~ Ie = 80A Icw = 12Ie (960A/1s) Icm = 20Ie (1600A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 2P100A	Ue = 400/415V~ Ie = 100A Icw = 12Ie (1200A/1s) Icm = 20Ie (2000A) Cat. AC-22A

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

Certificate of Suitability

Non declared	Switch-disconnector	CHINT	NH4-125 2P125A	Ue = 400/415V~ Ie = 125A Icw = 12Ie (1500A/1s) Icm = 20Ie (2500A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 3P32A	Ue = 400/415V~ Ie = 32A Icw = 12Ie (384A/1s) Icm = 20Ie (640A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 3P40A	Ue = 400/415V~ Ie = 40A Icw = 12Ie (480A/1s) Icm = 20Ie (800A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 3P63A	Ue = 400/415V~ Ie = 63A Icw = 12Ie (756A/1s) Icm = 20Ie (1260A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 3P80A	Ue = 400/415V~ Ie = 80A Icw = 12Ie (960A/1s) Icm = 20Ie (1600A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 3P100A	Ue = 400/415V~ Ie = 100A Icw = 12Ie (1200A/1s) Icm = 20Ie (2000A) Cat. AC-22A

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

Certificate of Suitability

Non declared	Switch-disconnector	CHINT	NH4-125 3P125A	Ue = 400/415V~ Ie = 125A Icw = 12Ie (1500A/1s) Icm = 20Ie (2500A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 4P32A	Ue = 400/415V~ Ie = 32A Icw = 12Ie (384A/1s) Icm = 20Ie (640A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 4P40A	Ue = 400/415V~ Ie = 40A Icw = 12Ie (480A/1s) Icm = 20Ie (800A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 4P63A	Ue = 400/415V~ Ie = 63A Icw = 12Ie (756A/1s) Icm = 20Ie (1260A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 4P80A	Ue = 400/415V~ Ie = 80A Icw = 12Ie (960A/1s) Icm = 20Ie (1600A) Cat. AC-22A
Non declared	Switch-disconnector	CHINT	NH4-125 4P100A	Ue = 400/415V~ Ie = 100A Icw = 12Ie (1200A/1s) Icm = 20Ie (2000A) Cat. AC-22A

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

Certificate of Suitability

Non declared	Switch-disconnector	CHINT	NH4-125 4P125A	Ue = 400/415V~ Ie = 125A Icw = 12Ie (1500A/1s) Icm = 20Ie (2500A) Cat. AC-22A
--------------	---------------------	-------	----------------	---

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Suitable for sale in New Zealand

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

