



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240307008982

Product

Soft Starter

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NJRP5-180/D6,NJRP5-220/D6,NJRP5-264/D6,NJRP5-320/D6,NJRP5-370/D6,
NJRP5-180/D4,NJRP5-220/D4,NJRP5-264/D4,NJRP5-320/D4,NJRP5-370/D4

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0307-014668, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-2:2023

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jun.26,2024

Valid until: May.19,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 3

Certificate No.: CE240307008982

NJRP5-180/D6,NJRP5-220/D6,NJRP5-264/D6,NJRP5-320/D6,NJRP5-370/D6,
NJRP5-180/D4,NJRP5-220/D4,NJRP5-264/D4,NJRP5-320/D4,NJRP5-370/D4

Uimp: 8kV;

Ui: See Table 1;

Ith: See Table 1;

Ue: See Table 1;

Ie: See Table 1;

Pe: See Table 1;

AC-53b;

Pole:3P;

IP20

Table 1

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-180/D6	45kW (Ue=AC220V)	167A	167A	AC200-AC690V	1000V
	90kW (Ue=AC380V)				
	110kW (Ue=AC460V)				
	132kW (Ue=AC575V)				
	160kW (Ue=AC690V)				
NJRP5-220/D6	55kW (Ue=AC220V)	207A	207A		
	110kW (Ue=AC380V)				
	132kW (Ue=AC460V)				
	160kW (Ue=AC575V)				
	200kW (Ue=AC690V)				
NJRP5-264/D6	75kW (Ue=AC220V)	248A	248A		
	132kW (Ue=AC380V)				
	150kW (Ue=AC460V)				
	185kW (Ue=AC575V)				
	250kW (Ue=AC690V)				
NJRP5-320/D6	90kW (Ue=AC220V)	300A	300A		
	160kW (Ue=AC380V)				



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 3

Certificate No.: CE240307008982

	185kW (Ue=AC460V)				
	250kW (Ue=AC575V)				
	315kW (Ue=AC690V)				
NJRP5-370/D6	110kW (Ue=AC220V)	349A	349A		
	185kW (Ue=AC380V)				
	220kW (Ue=AC460V)				
	280kW (Ue=AC575V)				
	355kW (Ue=AC690V)				

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-180/D4	45kW (Ue=AC220V)	167A	167A	AC200-AC415V	660V
	90kW (Ue=AC380V)				
	90kW (Ue=AC415V)				
NJRP5-220/D4	55kW (Ue=AC220V)	207A	207A		
	110kW (Ue=AC380V)				
	110kW (Ue=AC415V)				
NJRP5-264/D4	75kW (Ue=AC220V)	248A	248A		
	132kW (Ue=AC380V)				
	132kW (Ue=AC415V)				
NJRP5-320/D4	90kW (Ue=AC220V)	300A	300A		
	160kW (Ue=AC380V)				
	160kW (Ue=AC415V)				
NJRP5-370/D4	110kW (Ue=AC220V)	349A	349A		
	185kW (Ue=AC380V)				



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE


CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 3 of 3

Certificate No.: CE240307008982

	185kW (Ue=AC415V)				
--	-------------------	--	--	--	--



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE