



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220306007624

Product Voltage Protection Relay

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NJYB2-G,NJYB2-H;

Technical data Ui:415V;Uimp:4kV;Ith:3A;AC-15:Ue/Ie:AC415V/0.47A;IP
20.

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-24D0001-S, the submitted sample(s) of the above item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Feb.19,2024

Valid until: Apr.06,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE