

IEC**IECEE**

Ref. Certif. No.

CN48669-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Voltage Protection Relay

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.2, Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui:415V;Uimp:4kV;
AC-15:Ue/Ie:AC220V/0.75A,AC230V/0.75A,AC240V/0.75A,
AC380V/0.47A,AC400V/0.47A,AC415V/0.47A;Ith:3A;IP20

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NJYB3;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN48669, dated 2019-11-04.
The issuance of the M1 certificate is to change suppliers of
critical components.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-089119-M1

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Apr.02,2024

Signature:

Xie ZhaoXu