

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO  
**COLORFUL TRADING WESTERN CAPE cc**

IN TERMS OF SANS 10142 CLAUSE 4.  
*ISSUED BY*

**National Regulator for Compulsory Specifications**

*PRODUCT: EARTH LEAKAGE SWITCHES - ELSWs (CHINT) NL1-63 \*;*  
 *$U_n = 230/240V \sim 2P(1P+N)$ ,  $400/415V \sim 4P(3P+N)$ ;  $U_{imp} = 4kV$ ;  $I_n = 16, 25, 32, 40, 63A$ ;*  
 *$I_{cs} = 500/630A$ ;  $I_{cw} = 4.5/6/10kA$ ;  $I_{\Delta n} = 0.01/0.03/0.5A$ ; 50/60Hz; type A and AC*

***Test Laboratory:***

Intertek Testing Services Shanghai

**Test report no:** 220901789SHA-001

**RCC No:** 2305043

*UFA*  
**NRCS-Acting Electrotech General Manager.**



***In accordance to(Standards):***

VC8035:1987 + Amendment:1990  
SANS 556-2-2: 2015

**Period of Validity**

22/05/2023 to 22/05/2026

**DATE** 26-05-2023