



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-200617-EA

Certificate Holder: Zhejiang Chint Electrics Co., Ltd
No. 1, Chint Road,
Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang Province, 325603
P.R. China

Regulatory Definition: Residual Current Device
Product Description: Type B residual current operated circuit breaker (RCCB)
Trade Name: CHINT
Model No.: NL210
Markings: Ue: 230/240Vac (1P+N), 400/415Vac (3P+N), 50Hz
In: 25, 40, 63A
IΔn: 0.03, 0.1, 0.3A Type B
Inc=IΔc: 10kA
IΔm: 500A, 630A

Standard: IEC 62423:2009
AS/NZS 61008.1:2015

Conditions: Nil

Approval Mark: RCM and SAA-200617-EA

Date First Registered: 8 April 2020

Date of Expiry: 8 April 2025

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 08-04-20 200617/1