

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electric Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

For the product: Type B residual current operated circuit-breakers (RCCBs)

Trade name: CHINT

Type/Model: NL210

Ratings: 1P+N, 3P+N
U_e = 230 / 240 Vac for 1P+N, 400 / 415 Vac for 3P+N, 50 Hz
I_n = 25, 40, 63 A
I Δ n = 0,03, 0,1, 0,3 A, type B, without time-delay
I_{nc} = I Δ c = 10 kA, I Δ m = I_m: 500 A and 10 I_n whichever is greater

Manufactured by: Zhejiang Chint Electric Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

Requirements: BS EN 61008-1:2012+A12:2017, BS EN 61008-2-1:1995
BS EN 62423:2012

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3316987.50 issued on 2020-03-16.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

Wenzhou, Zhejiang, 2 August 2021

Number: 3322003.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

J. Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

UK
CA