ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueging,

325603 Zhejiang, China

For the product: Thermal overload relay

Trade name: CHINT

Type/Model: NR2-36

Ratings: 380 / 400 / 415 Vac, 660 Vac,

23-32 A, 28-36 A

See annex for further ratings

Manufactured by: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,

325603 Zhejiang, China

Requirements: BS EN IEC 60947-4-1:2019, BS EN 60947-5-1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3316368.50 issued on 2019-09-11 and 3316366.51 issued on 2019-09-05.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

Wenzhou, Zhejiang, 6 August 2021/////Number: 3322009.01A

DEKRA Testing Services (Zhejiang) Co., L/td

J. Guo Certification Manager

© Integral publication of this attestation and adjoining reports is allowed



T +86 57762 868000 F +86 57762 919889 www.dekra-product-safety.com



Annex

Document no. 3322009.01A

Ratings:

product Thermal Overload Relay

trade name(s) CHINT type(s) NR2-36

kind of equipment Thermal Overload Relay

number of poles kind of current (a.c. or d.c.) a.c interrupting medium Air

method of operation Automatic and by hand

rated frequency 50/60 Hz

rated duties Uninterrupted operation duty

Rated and limiting values, main circuit As below

rated operational voltage Ue (V) 380/400/415, 660 Vac

rated insulation voltage Ui (V) 690 V rated impulse withstand voltage Uimp(kV) 6 kV conventional free air thermal current Ith (A) 36 A

rated operational current le (A) or rated 23-32 A, 28-36 A

operational powers

rated uninterrupted current lu (A) Equal to le

rated prospective short-circuit current "r" (kA) 3 kA rated conditional short-circuit current lq (kA) 50 kA 1

type of co-ordination

SCPD Fuse: RT36-1 (NT1)

gG 80 A, 690 Vac, 50 kA Manufacturer is CHINT,

Flexible and rigid stranded wire: 1,5 mm²-10 mm² **Terminal Terminations** One side, screw terminals, one conductor per terminal

Other side, pins to be connected to contactors

Auxiliary circuits As below

rated operational voltage Ue (V) AC-15: 380 Vac, 220 Vac, DC-13: 220 Vdc

rated insulation voltage: Ui (V) 690 V rated impulse withstand voltage Uimp(kV) 6 kV

rated operational current: le (A) AC-15, 1,58 A at 380 Vac, 2,73 A at 220 Vac

DC-13, 0,2 A at 220 Vdc

kind of current AC or DC rated frequency: (Hz) 50/60 Hz number of circuits

number and kind of contact elements 1NO and 1NC rated uninterrupted current: lu (A) Equal to le

utilization category: (AC, DC, current and AC-15, 1,58 A at 380 Vac, 2,73 A at 220 Vac

DC-13, 0,2 A at 220 Vdc voltage)

As below Short-circuit characteristic

Rated conditional short-circuit current (kA) 1 kA kind of protective device

Fuse: RT36-00 (NT00) 6 A, 500 Vac, 120 kA Manufacturer is CHINT