



Ref. Certif. No.

CN47922

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal Overload Relays

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.  
No.2, Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NR8-100

Additional information (if necessary may also be reported on page 2)

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012

A sample of the product was tested and found to be in conformity with

03601-A-19CB0034-S-A;03601-A-19CB0034-S-B

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn



Date: Aug.26,2019

Signature:

Lu Mei

CB 0053238

NR8-100

Uimp:6kV;

Ui:690V;

Ue: AC660V/690V;

Ie: 23-32A,30-40A,37-50A,48-65A,55-70A,63-80A,80-93A,80-100A;

Tripping class:10A;

3P;

IP20(After mounting);

Attached auxiliary contact (1NO1NC):

Uimp:6kV;

Ui:690V;

Ith:5A;

Ue/Ie:

AC-15: AC380V/400V/1.5A

DC-13:DC220V/0.2A

Page 1 of 1

Additional information (if necessary)

Date: Aug.26,2019

Signature: 

Lu Mei