

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN33863-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Electronic Overload Relays

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.2, Changjiang Road, CHINT Intelligent Electric
Appliance Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V;Uimp: 6kV;Ue:AC660/690V; Ie: 80-160A,
100-200A;Trip class: 10A;Number of poles: 3P;Auxiliary
contacts (body contact):Ith: 5A;AC-15: Ue/Ie:
220/230V/2.5A, 380/400V/1.5A;DC-13: Ue/Ie: 220V/0.2A;
1NO1NC

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be
reported on page 2)

NXR-200,NR8-200;

A sample of the product was tested and found
to be in conformity withThe latest CB No. is CN33863-M1,dated 2016-04-12. The
new certificate has been issued to add NR8-200.As shown in the Test Report Ref. No. which
forms part of this Certificate

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012

00901-CB2014CQC-063745-M2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Oct.12,2019

Signature:

Lu Mei

CB 0054195