

**IEC****IECEE**

Ref. Certif. No.

CN58814-M1

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Electronic Overload Relay

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Zhejiang CHINT Electrics Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Ratings and principal characteristics

Ui:690V;Uimp:6kV;Ue:AC690V;Ie:0.6-1.2A,1.2-2.4A,2-4A,4-8A,5-10A,7-12 A,10-20A,20-25A,22-32A; Trip class:10A,10,20(3 options 1);3P;IP20(Front Side);Auxiliary contact:1NO1NC;Ith:5A; AC-15:  
Ue/Ie:AC230V/2.5A,AC400V/1.5A;DC-13: Ue/Ie:DC220V/0.2A

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NRE8-25

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN58814, dated 2023-01-04. The M1 certificate has been issued to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-104205-M1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.16,2023

Signature:

Xie ZhaoXu

