

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

COLOURFUL TRADING WESTERN CAPE (Pty)Ltd

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTIVE DEVICE (CHINT)

NU6-IIIG/**, NU6-IIIG/F*/***

$U_c=255/320V\sim$; $I_{max}=65kA$; $U_p=1.8kV$; $I_n=30kA$; 50/60Hz

Test Laboratory:

INTERTEK TESTING SERVICES SHANGHAI

Test Report No(s): 19030211ISHA-001

In accordance to(Standards):

IEC 61643-11:2011

RCC No: 2111087

Period of Validity

20/12/2021 to 20/12/2024

NRCS Electro-Tech General Manager



DATE

20-12-2021