Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant CE mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address	:	**Zhejiang Chint Electrics Co., Ltd.** **No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P. R. China**
Manufacturing site Name & Address		**Zhejiang Chint Electrics Co., Ltd.** **No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P. R. China**
Product(s) Tested	:	**Surge protective device**
Ratings and principal characteristics	:	**Type 2 SPD, See Annex for details.**
Model(s)	:	**NU6-II */* *, NU6-II/F */* * (The first "*"= 40, 60 or 100; The second "*"= 385 or 460; The third "*"= 1P, 2P, 3P or 4P.) (Details see annex)**
Brand name	:	CHNT
Relevant Standard(s) / Specification(s) / Directive(s)	:	**EN 61643-11:2002+A11:2007 the Low Voltage Directive 2006/95/EC**
Verification Issuing Office Name & Address	:	**Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China**
Verification Number	:	**130501571SHA-V1**
Report Number(s)		**130501571SHA-001**

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

CE

Oliver Wei
Manager
November 14, 2013

Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with 130501571SHA-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233,

Type 2 SPD, partially accessible, with mechanical indicator, with internal disconnector with fusible metal Sn alloy, with or without signalling contact.
Totally 48 models.

Ratings:

Model	Protected mode	I_{max}(kA)	I_n(kA)	U_c(V)	U_p(kV)	LV System	Client declared external disconnector	I_{SCCR}
NU6-II 40/385 1P	1xL-PE, alternative 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II 60/385 1P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II 100/385 1P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II 40/460 1P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II 60/460 1P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II 100/460 1P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II 40/385 2P	1xL-PE, 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II 60/385 2P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II 100/385 2P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II 40/460 2P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II 60/460 2P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II 100/460 2P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II 40/385 3P	3xL-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II 60/385 3P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II 100/385 3P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II 40/460 3P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II 60/460 3P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II 100/460 3P		100	40		2.0		250A gL/gG fuse	3kA

Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with 130501571SHA-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233,

NU6-II 40/385 4P	3xL-PE, 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II 60/385 4P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II 100/385 4P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II 40/460 4P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II 60/460 4P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II 100/460 4P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II/F 40/385 1P	1xL-PE, alternative 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II/F 60/385 1P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II/F 100/385 1P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II/F 40/460 1P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II/F 60/460 1P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II/F 100/460 1P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II/F 40/385 2P	1xL-PE, 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II/F 60/385 2P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II/F 100/385 2P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II/F 40/460 2P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II/F 60/460 2P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II/F 100/460 2P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II/F 40/385 3P	3xL-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II/F 60/385 3P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II/F 100/385 3P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II/F 40/460 3P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II/F 60/460 3P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II/F 100/460 3P		100	40		2.0		250A gL/gG fuse	3kA
NU6-II/F 40/385 4P	3xL-PE, 1xN-PE	40	15	385	1.8	TN	125A gL/gG fuse	5kA
NU6-II/F 60/385 4P		60	25		1.8		160A gL/gG fuse	3kA
NU6-II/F 100/385 4P		100	40		1.8		250A gL/gG fuse	3kA
NU6-II/F 40/460 4P		40	15	460	2.0		125A gL/gG fuse	5kA
NU6-II/F 60/460 4P		60	25		2.0		160A gL/gG fuse	3kA
NU6-II/F 100/460 4P		100	40		2.0		250A gL/gG fuse	3kA

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

Oliver Wei
Manager
November 14, 2013