



Ref. Certif. No.

SE-112572

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Low-voltage switchgear and controlgear - Part 2: circuit-breakers
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory	Same as applicant
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NXB-63G
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	2309A0765SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Date: 17 November, 2023

intertek

Signature:

Fredrik Wennersten



Ref. Certif. No.

**SE-112572**

### Factories

Ue= AC220V/230V/240V (1P), AC380V/400V/415V (2P, 3P, 4P)

In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A

Icu= Ics= 6kA, Cat.A, li= 14,2In, 10In

Ref. temperature: +40°C, 50/60Hz

Date: 17 November, 2023

Signature:

A handwritten signature in black ink, appearing to be 'J. L. A.', is written over the signature line.