

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers with integral overcurrent protection
(RCBO)

Trade name: CHINT

Type/Model: NXBL-40Y

Ratings: 1P+N, Ue: 220 / 230 / 240 Vac, 50 / 60 Hz, In: 2, 4, 6, 10, 13, 16, 20, 25, 32, 40 A
B and C type, I Δ n: 30, 100, 300 mA, type A and AC, without time-delay
Ics = 4,5 / 6 / 7,5 kA, Icn = 4,5 / 6 / 10 kA, I Δ m = 3 kA, energy limiting class 3

Manufactured by: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

Subject: Type Test

Requirements: EN 61009-1:2012, EN 61009-1:2012/A1:2014, EN 61009-1:2012/A2:2014,
EN 61009-1:2012/A11:2015, EN 61009-1:2012/A12:2016,
EN 61009-1:2012/A13:2021, EN 61009-2-1:1994, EN 61009-2-1:1994/A11:1998,
IEC 61009-1:2010, IEC 61009-1:2010/A1:2012, IEC 61009-1:2010/A2:2013,
IEC 61009-2-1:1991

Remark: This Attestation is based on AoC no. 3330831.01-AOC issued on 2024-05-08.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no. 3330833.50 issued on 2024-05-27, 3330831.50 issued on 2024-04-29, 3318200.50 issued on 2020-08-21, 3316675.50 issued on 2019-10-11, 3314711.50 issued on 2018-11-09, 3310241.50 issued on 2016-08-09, 3306652.50 issued on 2014-10-28, 3302588.52 issued on 2011-10-17, 3302588.50 issued on 2011-08-22 and W0811042.50 issued on 2009-08-13.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 31 May 2024

Number: 3330833.01-AOC

DEKRA Testing Services (Zhejiang) Co., Ltd.
Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing Services (Zhejiang) Co., Ltd.
No. 5, Changjiang Road, Great Bridge Industrial Park, North Baixiang, 325603 Wenzhou, Zhejiang, China
T +86 57762 868000 F +86 57762 919889 www.dekra-certification.com

