

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO  
**COLORFUL TRADING WESTERN CAPE cc**

IN TERMS OF SANS 10142 CLAUSE 4.  
ISSUED BY

**National Regulator for Compulsory Specifications**

PRODUCT: EARTH LEAKAGE CIRCUIT-BREAKERS (CHINT) NXBLE-63Y  
 $U_e = 240V \sim (1P+N)$ ;  $U_i = 500V$ ;  $U_{imp} = 4kA$ ;  $I_n = 63A$ ;  $I_{\Delta n} = 30mA$ ;  $I_{\Delta m} = 2000A$ ;  
 $I_i = 10In$ ;  $I_{nc} = 6kA$ ;  $I_{cu} = 4,5kA$ ; 50/60Hz; IP20; type AC

### Test Laboratory:

Intertek Testing Services Shanghai

Test report no: 2306A0286SHA-001

RCC No: 2403040



**NRCS - Electrotechnical General Manager.**

### In accordance to (Standards):

VC 8035:1987 + AMD:1990

SANS 556-2-1:2018

SANS 60947-2:2016 + A1:2019

Period of Validity

19/03/2024 to 19/03/2027



DATE 25 MARCH 2024