


Test Verification of Conformity

Verification Number: 200401948SHA-V2

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China 325603
Manufacturing site Name & Address:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China 325603
Product Description:	Low-voltage switchgear and controlgear: Contactors and motor- starters
Ratings & Principle Characteristics:	See Annex pages
Models/Type References:	NXC-120, NXC-120/N, NXC-160, NXC-160/N, NXC-185, NXC-185/N, NXC-225, NXC-225/N, NXC-265, NXC-265/N, NXC-330, NXC-330/N, NXC-400, NXC-400/N, NXC-500, NXC-500/N, NXC-630, NXC-630/N
Brand Name(s):	
Standard(s)/Directive(s):	EN 60947-4-1: 2019 and EN 60947-5-1: 2017 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2020-03-18 to 2020-05-15
Test Report Number(s):	200401948SHA-009, -010, -011, -012, -013, -014



Signature

Name: Oliver Wei

Position: Manager

Date: 28 June 2020

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200401948SHA-V2

Model: NXC-120, NXC-120/N
 Main circuit Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=200A(AC-1)$, $I_r=5kA/690V$, $I_q=50kA/415V$,
 $U_s= AC: 110, 127, 220, 230, 240, 380, 400, 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 120 \quad 120 \quad 86 \quad 120 \quad 120 \quad 86$

Model: NXC-160, NXC-160/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=200A(AC-1)$, $I_r=5kA/690V$, $10kA/415V$, $I_q=50kA/415V$,
 $U_s= AC: 110, 127, 220, 230, 240, 380, 400, 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 160 \quad 160 \quad 107 \quad 160 \quad 160 \quad 107$

Model: NXC-185, NXC-185/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=275A(AC-1)$, $I_r=5kA/690V$, $10kA/415V$, $I_q=50kA/415V$,
 $U_s= AC: 110, 127, 220, 230, 240, 380, 400, 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 185 \quad 185 \quad 107 \quad 160 \quad 160 \quad 107$

Model: NXC-225, NXC-225/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=275(AC-1)$, $I_r=5kA/690V$, $10kA/415V$, $I_q=50kA/415V$,
 $U_s= AC: 110, 127, 220, 230, 240, 380, 400, 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 225 \quad 225 \quad 118 \quad 185 \quad 185 \quad 107$

Auxiliary contact: AX-3C/11(1NC1NO)
 Ratings: $I_{th}=10A$, conditional short-circuit current: 1kA
 Category: AC-15 DC-13
 $U_e(V): 380/400/415V \quad 220V$
 $I_e(A): 1,5 \quad 0,3$

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200401948SHA-V2

Model: NXC-265, NXC-265/N
 Main circuit Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=315A(AC-1)$, $I_r=10kA/690V$, $I_q=50kA/415V$,
 $U_s= AC/DC: 110\sim 127V, 220\sim 240V, 380\sim 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 265 \quad 265 \quad 170 \quad 265 \quad 265 \quad 137$

Model: NXC-330, NXC-330/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=380A(AC-1)$, $I_r=10kA/690V$, $18kA/415V$, $I_q=50kA/415V$,
 $U_s= AC/DC: 110\sim 127V, 220\sim 240V, 380\sim 415V, 50/60Hz$
 Category AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 330 \quad 330 \quad 235 \quad 330 \quad 330 \quad 170$

Model: NXC-400, NXC-400/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=450A(AC-1)$, $I_r=10kA/690V$, $18kA/415V$, $I_q=50kA/415V$,
 $U_s= AC/DC: 110\sim 127V, 220\sim 240V, 380\sim 415V, 50/60Hz$
 Category AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 400 \quad 400 \quad 303 \quad 330 \quad 330 \quad 235$

Auxiliary contact: AX-3C/11B(1NC1NO)
 Ratings: $I_{th}=10A$, conditional short-circuit current: 1kA
 Category AC-15 DC-13
 $U_e(V): 380/400/415V \quad 220V$
 $I_e(A): 1,5 \quad 0,3$

Model: NXC-500, NXC-500/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=630A(AC-1)$, $I_r=18kA/690V$, $I_q=50kA/415V$,
 $U_s= AC/DC: 110\sim 127V, 220\sim 240V, 380\sim 415V, 50/60Hz$
 Category: AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 500 \quad 500 \quad 353 \quad 500 \quad 500 \quad 303$

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200401948SHA-V2

Model: NXC-630, NXC-630/N
 Ratings: 3P, $U_i=1000V$, $U_{imp}=12kV$, $I_{th}=700A(AC-1)$, $I_r=18kA/690V$, $I_q=50kA/415V$,
 $U_s= AC/DC: 110\sim 127V, 220\sim 240V, 380\sim 415V, 50/60Hz$
 Category AC-3 AC-4
 $U_e(V): 220/230/240 \quad 380/400/415 \quad 660/690 \quad 220/230/240 \quad 380/400/415 \quad 660/690$
 $I_e(A): 630 \quad 630 \quad 400 \quad 630 \quad 500 \quad 353$

Auxiliary contact: AX-3C/11B(1NC1NO)
 Ratings: $I_{th}=10A$, conditional short-circuit current: 1kA
 Category AC-15 DC-13
 $U_e(V): 380/400/415V \quad 220V$
 $I_e(A): 1,5 \quad 0,3$

Remark : The product with /N means reversible contactor



Signature

Name: Oliver Wei
Position: Manager
Date: 28 June 2020