



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230305008549

Product Contactor For Capacitor Switching

Applicant Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NXCC-32**, NXCC-43**;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2023)FQIIDQCE-0328, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Oct.13,2023

Valid until: Oct.12,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230305008549

NXCC-32**, NXCC-43**

(**=Type and quantity of auxiliary contacts);

Ui:690V;Uimp:6kV;

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

NXCC-32**:Ith:32A;AC-6b:

Ue/Ie:AC220V/230V/30.4A,

AC380V/400V/30.4A,AC660V/690V/30.4A;Qe:AC220V/230V/11.5kvar,AC380V/400V/20kvar,AC660V/690V/34.7kvar;

NXCC-43**:Ith:43A;AC-6b:

Ue/Ie:AC220V/230V/39.4A,

AC380V/400V/39.4A,AC660V/690V/39.4A;Qe:AC220V/230V/15kvar,

AC380V/400V/25.9kvar,

AC660V/690V/45kvar;

Us:AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC208V,AC220V,AC230V,

AC240V,AC277V,AC380V,AC400V,AC415V,

AC440V,AC460V,AC480V,AC525V,AC600V,

AC660V/50Hz,50/60Hz,60Hz;

3P;IP20(Only applicable to the front side);

Attached auxiliary contacts:

2NO1NC,1NO2NC;Ui:690V;Uimp:6kV;

Ith:10A;AC-15:Ue/Ie:AC220V/230V/2.7A,

AC380V/400V/1.5A;DC-13:Ue/Ie:DC220V/0.3A



CHINA QUALITY CERTIFICATION CENTRE