CERTIFICATE

Issued to: Applicant: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China

Licensee: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China

Product Trade name(s) Type(s)/model(s) : Moulded-Case Circuit Breaker : CHINT : NXM-1250H, NXM-1250S, NXM-1600H, NXM-1600S, NXMH-1250H, NXMH-1250S, NXMH-1600H, NXMH-1600S, NXMP-1250H, NXMP-1250S, NXMP-1600H and NXMP-1600S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2;2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEVR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on/9 April 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-103160

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL



Rosa Zhou Certification Manager





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396



page 1 of 3

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data	
Product	: Moulded-Case Circuit Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NXM-1250H, NXM-1250S, NXM-1600H, NXM-1600S,
	NXMH-1250H, NXMH-1250S, NXMH-1600H, NXMH-1600S,
	NXMP-1250H, NXMP-1250S, NXMP-1600H and NXMP-1600S
Number of poles	: 3P and 4P (unprotected N pole or protected N pole)
Protected pole	: 3 or 4
Rated operational voltage (Ue) Rated insulation voltage (Ui)	: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac : 1000 Vac
Rated impulse withstand voltage	: 12 kV
(Uimp)	. 12 KV
Rated operational current (le)	: Equal to In
	: Equal to In
Current rating for four-pole circuit-	: Equal to In
breakers	
Rated frequency	: 50 / 60 Hz
Reference temperature	: 40 °C or 55 °C
Suitable for isolation Selectivity category	: Suitable : A
Safety distance (screen-circuit	: Front / Back: 0 mm,
breaker)	Left / Right: 100 mm,
Si caller)	Up / Down: 100 mm
Instantaneous release	: Magnetic type, adjustable,
	2 poles in series: li: (7, 8, 9, 10) x In
	single pole: 1,2 x li
Time setting of the instantaneous	: Fixed
release	Thermal time. Final enadimetable in (0.7, 0.0, 0.0, 4.0) with
Inverse time delay release Time setting of the inverse time	: Thermal type, Fixed or adjustable Ir: (0,7, 0,8, 0,9, 1,0) x In : Fixed, trip time at 2 In: 3 min ≤ t ≤ 30 min
delay release	. Fixed, the time at 2 m s min $2 \text{ t} 2 50 \text{ min}$
Method of mounting	: Fixed
EMC environment	: A and B
Individual pole short-circuit breaking	: 19,2 kA at 415 Vac
capacity (lit)	
Rated tightening torque for terminals	: 30 Nm
Line/load terminal	: Marked
Connection	: Copper bar
Product data – type NXM-1250H	
Rated current (In)	: 1000 A, 1250 A
Rated service short-circuit breaking	: 75 kA at 220 Vac / 230 Vac / 240 Vac,
capacity (Ics)	50 kA at 380 Vac / 400 Vac / 415 Vac
Rated ultimate short-circuit breaking	: 100 kA at 220 Vac / 230 Vac / 240 Vac
capacity (Icu)	70 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXM-1250S	
Rated current (In)	: 1000 A, 1250 A
Rated service short-circuit breaking	: 50 kA at 220 Vac / 230 Vac / 240 Vac,
capacity (Ics)	36 kA at 380 Vac / 400 Vac / 415 Vac
Rated ultimate short-circuit breaking	: 75 kA at 220 Vac / 230 Vac / 240 Vac
capacity (Icu)	50 kA at 380 Vac / 400 Vac / 415 Vac



page	2 (of (3
------	-----	------	---

Product data – type NXM-1600H Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A, 1600 A 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXM-1600S Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A, 1600 A 50 kA at 220 Vac / 230 Vac / 240 Vac, 36 kA at 380 Vac / 400 Vac / 415 Vac 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMH-1250H Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMH-1250S Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A 50 kA at 220 Vac / 230 Vac / 240 Vac, 36 kA at 380 Vac / 400 Vac / 415 Vac 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMH-1600H Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A, 1600 A 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMH-1600S Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A, 1600 A 50 kA at 220 Vac / 230 Vac / 240 Vac, 36 kA at 380 Vac / 400 Vac / 415 Vac 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMP-1250H Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)	 1000 A, 1250 A 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
Product data – type NXMP-1250S Rated current (In)	: 1000 A, 1250 A

ANNEX TO KEMA-KEUR CERTIFICATE 33-103160



Rated service short-circuit breaking capacity (lcs) Rated ultimate short-circuit breaking capacity (lcu)

Product data – type NXMP-1600H

Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu)

Product data - type NXMP-1600S

Rated current (In) Rated service short-circuit breaking capacity (Ics) Rated ultimate short-circuit breaking capacity (Icu) 1000 A, 1250 A, 1600 A
50 kA at 220 Vac / 230 Vac / 240 Vac, 36 kA at 380 Vac / 400 Vac / 415 Vac
75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac

: 50 kA at 220 Vac / 230 Vac / 240 Vac,

: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac

: 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac

: 100 kA at 220 Vac / 230 Vac / 240 Vac

70 kA at 380 Vac / 400 Vac / 415 Vac

: 1000 A, 1250 A, 1600 A

36 kA at 380 Vac / 400 Vac / 415 Vac

TESTS

Test requirements

EN 60947-2:2017

Test result

The test results are laid down in DEKRA test file 331200100.

Additional information

NXM - 1600 H / 4 300 T B a b c d e f a = Model name: 'NXM', 'NXMP', 'NXMH' b = Frame size: '1250' or '1600' c = Short-circuit capacity: 'S', 'H' d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs e = 'T' means overload release is adjustable f = For Neutral pole, 'B' means unprotected N pole, 'C' means protected N pole

The referred test report is 3312001.50.

The product also complies with IEC 60947-2:2016.

Conclusion

The examination proved that all requirements were met.

Factory location

Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, Wenzhou, Zhejiang, China page 3 of 3