## ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueging,

325603 Zhejiang, China

For the product: Moulded-Case Circuit Breaker

Trade name: CHINT

Type/Model: NXM-800S, NXM-800H, NXM-800F, NXMH-800S, NXMH-800H, NXMH-800F,

NXMP-800S, NXMP-800H and NXMP-800F

Ratings: Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac / 50 / 60 Hz

Ui: 1000 Vac, Uimp: 12 kV In: 630 A, 700 A, 800 A

3P and 4P (N pole with or without overcurrent protection)

See annex for further ratings,

Manufactured by: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueging,

325603 Zhejjang, China

Subject: Type test

Requirements: EN/60947-2:2017/EN/60947-2:2017/+/K1/2020,

IEC 60947-2:2016, IEC 60947-2:2016/4/A1:2019

Remark: This attestation replaces AOC no./3320057.01A/issued/on/2021-03-22.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no. 3324489.50 and 3324489.51 issued on 2022-04-26.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 07 May 2022 Number: 3324489.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo

Certification Manager

© Integral publication of his attestation and adjoining reports is allowed







**Ratings** 

number of poles : 3P and 4P (N pole with or without overcurrent protection)

protected pole : 3 or 4

rated operational voltage (Ue) : 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac

rated insulation voltage (Ui) : 1000 V rated impulse withstand voltage : 12 kV

(Uimp)

rated current (In) 630 A, 700 A, 800 A

conventional thermal current (Ith) : Equal to In current rating for four-pole circuit : Equal to In

breakers

rated frequency : 50 / 60 Hz reference temperature : 40 °C or 55 °C suitable for isolation : Suitable

selectivity category : A

safety distance (screen-circuit : Front / Back: 0 mm, Left / Right: 100 mm,

Up / Down: 100 mm Magnetic type, fixed,

instantaneous release : Magnetic type, fixed, 2 poles in series: Ii = 10 In

time setting of the instantaneous : Fixed

release

inverse time delay release : Thermal type, Fixed or adjustable Ir:  $(0,7,\,0,8,\,0,9,\,1,0)$  x In

time setting of the inverse time : Fixed, trip time at 2 ln:  $2 \min \le t \le 18 \min$ 

delay release

method of mounting : Fixed EMC environment : A and B

individual pole short-circuit breaking : 9,6 kA at 415 Vac

capacity (lit)

rated tightening torque for terminals : 30 Nm line/load terminal : Marked

connection : Cable with lug or copper bar

## rating - NXM-800S/NXMP-800S/NXMH-800S

rated service short-circuit

50 kA at 220 Vac / 230 Vac / 240 Vac,
breaking capacity (Ics)

36 kA at 380 Vac / 400 Vac / 415 Vac
rated ultimate short-circuit

50 kA at 220 Vac / 230 Vac / 240 Vac
breaking capacity (Icu)

50 kA at 380 Vac / 400 Vac / 415 Vac
breaking capacity (Icu)

## rating - NXM-800H/NXMP-800H/NXMH-800H

rated service short-circuit

75 kA at 220 Vac / 230 Vac / 240 Vac,
breaking capacity (Ics)

50 kA at 380 Vac / 400 Vac / 415 Vac
rated ultimate short-circuit

100 kA at 220 Vac / 230 Vac / 240 Vac
breaking capacity (Icu)

70 kA at 380 Vac / 400 Vac / 415 Vac



## rating - NXM-800F/NXMP-800F/NXMH-800F

rated service short-circuit
75 kA at 220 Vac / 230 Vac / 240 Vac,
breaking capacity (Ics)
50 kA at 380 Vac / 400 Vac / 415 Vac
rated ultimate short-circuit
50 kA at 220 Vac / 230 Vac / 240 Vac,
breaking capacity (Icu)
50 kA at 380 Vac / 400 Vac / 415 Vac

Additional information Nomenclature breakdown:

 $\underline{NXM}$  -  $\underline{800}$   $\underline{H}$  /  $\underline{4}$  300  $\underline{T}$   $\underline{C}$ 

a bcd ef

a = Model name: 'NXM', 'NXMP', 'NXMH'

b = Frame size: '800"

c = Short-circuit capacity: 'F', 'H', 'S'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

e = 'Blank' means overload release is fixed, 'T' means overload release is adjustable

f = For Neutral pole, 'B' means N pole without overcurrent protection, 'C' means N pole with overcurrent protection