

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	Moulded-Case Circuit-Breaker
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, Wenzhou, Zhejiang China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ue: 220/230/240/380/400/415 Vac, 50/60 Hz Ui: 1000 V, Uimp: 12 kV, In: 800 A, 1000 A 3P and 4P (protected N pole) See annex for further ratings
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NXMS-1000H, NXMSH-1000H and NXMSP-1000H
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	3312009.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Ratings:

number of poles	:	3P and 4P (protected N pole)
protected pole	:	3 or 4
rated operational voltage (Ue)	:	220/230/240/380/400/415 Vac
rated insulation voltage (Ui)	:	1000 V
rated impulse withstand voltage (Uimp)	:	12 kV
rated current (In)	:	800 A, 1000 A
conventional thermal current (Ith)	:	Equal to In
current rating for four-pole circuit-breakers	:	0.5 In, 1 In, OFF
rated frequency	:	50/60 Hz
rated ultimate short-circuit breaking capacity (Icu)	:	100 kA at 220/230/240 Vac 70 kA at 380/400/415 Vac
rated service short-circuit breaking capacity (Ics)	:	75 kA at 220/230/240 Vac 50 kA at 380/400/415 Vac
rated short-time withstand current (Icw)	:	12 kA - 1 s at 220/230/240/380/400/415 Vac
suitable for isolation	:	Suitable
selectivity category	:	B
safety distance (screen-circuit breaker)	:	Front/Back: 0 mm, Left/Right: 100 mm, Up/Down: 100 mm
instantaneous release	:	Ii (instantaneous tripping setting): (2, 3, 4, 6, 8, 10, 12) x In or OFF
time setting of the instantaneous release	:	Fixed
inverse time delay release	:	Ir (inverse time delay tripping setting): 630, 660, 680, 700, 720, 750, 780, 800 A (In: 800 A) 630, 680, 720, 780, 820, 900, 950, 1000 A (In: 1000 A)
time setting of the inverse time delay release	:	12 s, 60 s, 100 s, 150 s with tolerance of $\pm 20\%$ (at 2 Ir) Trip time at 2 Ir: Set at 12 s: 12 s $\pm 20\%$ Set at 150 s: 150 s $\pm 20\%$
short time delay release	:	I _{sd} (short time delay tripping setting): (1.5, 2, 3, 4, 5, 6, 8) x Ir or OFF
time setting of short time delay release	:	t _{sd} (short time delay tripping setting): 0.3 s with tolerance of ± 0.06 s Non-tripping duration: 0.24 s
method of mounting	:	Fixed
EMC environment	:	A and B
Individual pole short-circuit breaking capacity (lit)	:	9,6 kA at 415 Vac
rated tightening torque for terminals	:	30 Nm
line/load terminal connection	:	Marked Copper conductor with cable lug or copper bar

Additional information

Nomenclature breakdown:

NXMS - 1000 H / 4 300

a b c d

a = Model name: 'NXMS', 'NXMSP', 'NXMSH'

b = Frame size: 1000

c = Short-circuit capacity: 'H'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs