# CERTIFICATE

Issued to: Applicant: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China

Licensee: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China

Product : Moulded-Case Circuit-Breaker Trade name(s) : CHINT Type(s)/model(s) : NXMS-250F, NXMS-250F, NXMSH-250F, NXMSH-250F, NXMSP-250F and NXMSP-250H

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 29 May 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-103915

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

Henk Barends Certification Manager





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396

**DEKRA** 



## SPECIFICATION OF THE CERTIFIED PRODUCT

Product data Product Trade name(s) Type(s)/model(s) Number of poles Protected pole Rated operational voltage (Ue) Rated insulation voltage (Ui) Rated impulse withstand voltage	<ul> <li>Moulded-Case Circuit-Breaker</li> <li>CHINT</li> <li>NXMS-250F, NXMS-250H, NXMSH-250F, NXMSH-250H, NXMSP-250F and NXMSP-250H</li> <li>3P and 4P (protected N pole)</li> <li>3 or 4</li> <li>220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac</li> <li>800 V</li> <li>8 kV</li> </ul>
(Uimp) Rated current (In) Conventional thermal current (Ith) Current rating for four-pole circuit- breakers	: 250 A : Equal to In : 0.5 In, 1 In, OFF
Rated frequency Rated service short-circuit breaking capacity (Ics) Rated short-time withstand current (Icw) Suitable for isolation Selectivity category	<ul> <li>50 / 60 Hz</li> <li>50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac</li> <li>12 In / 1 s at 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac</li> <li>Suitable</li> <li>A</li> </ul>
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 50 mm, Up / Down: 50 mm
Instantaneous release Time setting of the instantaneous release	<ul> <li>Ii (instantaneous tripping setting):</li> <li>(2, 3, 4, 6, 8, 10, 12) x In or OFF</li> <li>Fixed</li> </ul>
Inverse time delay release	: Ir (inverse time delay tripping setting): 125 A, 140 A, 150 A, 160 A, 180 A, 200 A, 225 A, 250 A
Time setting of the inverse time delay release	<ul> <li>12 s, 60 s, 80 s, 100 s with tolerance of ± 20% (at 2 lr) Trip time at 2 lr: Set at 12 s: 12 s ± 20%</li> <li>Set at 12 s: 12 s ± 20%</li> </ul>
Short time delay release	Set at 100 s: 100 s ± 20% : Isd (short time delay tripping setting): (1.5, 2, 3, 4, 5, 6, 8) x Ir or OFF
Time setting of short time delay release	<ul> <li>tsd (short time delay tripping setting):</li> <li>0.3 s with tolerance of ± 0.06 s</li> </ul>
Method of mounting EMC environment Individual pole short-circuit breaking	Non-tripping duration: 0.24 s Fixed A 2,4 kA at 415 Vac
capacity (lit) Rated tightening torque for terminals Line/load terminal Connection	: 12 Nm : Marked : Copper conductor with cable lug
<b>Product data – type NXMS-250F</b> Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product data – type NXMS-250H</b> Rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac



Product data – type NXMSH-250F Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product data – type NXMSH-250H</b> Rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product data – type NXMSP-250F</b> Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product data – type NXMSP-250H</b> Rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac

## TESTS

### **Test requirements**

EN 60947-2:2017

#### Test result

The test results are laid down in DEKRA test file 331200500.

#### Additional information

Nomenclature breakdown: NXMS - 250 H / 4 300 a b c d a = Model name: 'NXMS', 'NXMSP', 'NXMSH' b = Frame size: 250 c = Short-circuit capacity: 'F', 'H' d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

The referred test report is 3312005.50.

The product also complies with IEC 60947-2:2016.

#### **Conclusion** The examination proved that all requirements were met.

## Factory location

Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, Wenzhou, Zhejiang, China