

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product	Moulded-Case Circuit-Breaker
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the factory	Additional information on page 2
Note: When more than one factory, please report on page 2	Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, Wenzhou, Zhejiang China
Ratings and principal characteristics	Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz Ui: 1000 V, Uimp: 12 kV 3P and 4P (protected N pole) See annex for further ratings
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NXMS-400S, NXMSP-400S, NXMSH-400S, NXMS-630S, NXMSP-630S and NXMSH-630S
Additional information (if necessary may also be reported on page 2)	Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	3312006.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051, NL-6825 MJ Arnhem, Netherlands





Signature: H.L. Schendstok(

## ANNEX TO CB TEST CERTIFICATE NL-52379



page 1 of 2

Ratings: number of poles protected pole rated operational voltage (Ue) rated insulation voltage (Ui) rated impulse withstand voltage (Uimp)		3P and 4P (protected N pole) 3 or 4 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac 1000 V 12 kV
conventional thermal current (Ith) current rating for four-pole circuit- breakers	:	Equal to In 0,5 In, 1 In, OFF
rated frequency rated ultimate short-circuit breaking capacity (Icu) rated service short-circuit breaking capacity (Ics) rated short-time withstand current (Icw) suitable for isolation		50 / 60 Hz 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac 50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac 8 kA / 1 s at 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac Suitable B
selectivity category safety distance (screen-circuit breaker)	:	Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
instantaneous release	:	li (instantaneous tripping setting): (2, 3, 4, 6, 8, 10, 12) x In or OFF
time setting of the instantaneous release	:	Fixed
time setting of the inverse time delay release	:	12 s, 60 s, 100 s, 150 s with tolerance of ± 20% (at 2 lr) Trip time at 2 lr: Set at 12 s: 12 s ± 20% Set at 150 s: 150 s ± 20%
short time delay release	:	Isd (short time delay tripping setting):
time setting of short time delay release	;	(1,5, 2, 3, 4, 5, 6, 8) x Ir or OFF tsd (short time delay tripping setting): 0,3 s with tolerance of ± 0,06 s Non-tripping duration: 0,24 s
method of mounting EMC environment Individual pole short-circuit	:::::::::::::::::::::::::::::::::::::::	Fixed A and B 6,048 kA at 415 Vac
breaking capacity (lit) rated tightening torque for terminals line/load terminal connection	: : :	22 Nm Marked Copper conductor with cable lug
<b>Product rating - NXMS-400S</b> rated current (In) inverse time delay release	:	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A
Product rating - NXMSP-400S rated current (In) inverse time delay release	:	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A
Product rating - NXMSH-400S rated current (In)	:	400 A

#### ANNEX TO CB TEST CERTIFICATE NL-52379



page 2 of 2

inverse time delay release Individual pole short-circuit breaking capacity (lit)	:	Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A 3,84 kA at 415 Vac
<b>Product rating - NXMS-630S</b> rated current (In) inverse time delay release	:	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A
<b>Product rating - NXMSP-630S</b> rated current (In) inverse time delay release	:	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A
<b>Product rating - NXMSH-630S</b> rated current (In) inverse time delay release		630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A

### Additional information

Nomenclature breakdown:

<u>NXMS</u> - <u>630</u> <u>S</u> / <u>4</u> 300

bcd

а

a = Model name: 'NXMS', 'NXMSP', 'NXMSH' b = Frame size: '630', '400' c = Short-circuit capacity: 'S' d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs